

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. **01319** Issued **3-11-87**
 date

Job Location 538 Huddle Rd. address
 Lot Hartmans subdivision outlets
no. 9 & 10 sub-div or legal discript
 Issued By Eldon Huber
 building official Joe Goodell
 Owner Maumee Valley Trailer Ct. 592-9906
 name
 Address 538 Huddle Rd. tel.

Agent Unknown tel.
 builder-eng.-etc.

Description of Use Residential Trailer Park

Residential 69 no. dwelling units

Commercial Industrial

New Add'n. Alter Remodel X

Mixed Occupancy

Change of Occupancy

Estimated Cost \$ 6,000.00

ZONING INFORMATION N.A.

district <u>C</u>	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: N.A.

Size: Length Width Stories Ground Floor Area cu. ft.
 Height Building Volume (for demo. permit)

Electrical: Replace 5 existing 60 AMP services with new 100 AMP services

Plumbing: N.A. brief description

Mechanical: N.A. brief description

Sign: N.A. type Dimensions Sign Area

Additional Information: 5 Meter socket relieves req. work includes replacing meter (PAID) fused disconnects, and service wired to trailers, this permit covers work on the following 5 lots

Date 3-6-87 Applicant Signature James Goodell owner-agent CITY OF NAPOLEON

MAR 12 1987

White-Building Department Yellow-Applicant Pink-Electrical Inspector Green-Clerk-Treasurer Gold-County Auditor

<input type="checkbox"/>	BUILDING				
<input checked="" type="checkbox"/>	ELECTRICAL	\$50.00			\$50.00
<input type="checkbox"/>	PLUMBING				
<input type="checkbox"/>	MECHANICAL				
<input type="checkbox"/>	DEMOLITION				
<input type="checkbox"/>	ZONING				
<input type="checkbox"/>	SIGN				
	WATER TAP				
	SEWER TAP				
	TEMP. ELECT.				
	ADDITIONAL PLAN REVIEW		Struct. <u> </u> hrs		
			Elect. <u> </u> hrs		
	TOTAL FEES				\$50.00
	LESS MIN. FEES PAID				
	BALANCE DUE				

PERMIT
CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01319 Issued 3-11-87 date
 Job Location 518 HUDDLE RD address
 Lot HARTMAN'S SUBDIVISION sub-div or legal district
 Issued By FH building official
 Owner VOE COMPANY LLC 592-9906 tel.
MARSHALL VALLEY TRAILERS CT
 Address 518 HUDDLE RD name
 Agent UNKNOWN builder-eng.-etc. tel.
 Description of Use RESIDENCIAL
TRAILER PARK
 Residential 69 no. dwelling units
 Commercial Industrial
 New Add'n. Alter Remodel X
 Mixed Occupancy
 Change of Occupancy
 Estimated Cost \$ 6000.00

FEE	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	<u>50.00</u>		<u>50.00</u>
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW		Struct. <u> </u> hrs	
		Elect. <u> </u> hrs	
TOTAL FEES.....			<u>50.00</u>
LESS MIN. FEES PAID			
BALANCE DUE.....			

ZONING INFORMATION N.A.

district	lot dimensions	area	front yd	side yds	rear yd
<u>C</u>					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION: N.A.

Size: Length Width Stories Ground Floor Area
 Height Building Volume (for demo. permit) cu. ft.
 Electrical: REPLACE 5- EXISTING 60 AMP SERVICES WITH NEW 100 AMP SERVICES
 Plumbing: N.A. brief description
 Mechanical: N.A. brief description
 Sign: N.A. type Dimensions Sign Area
 Additional Information: 5- METER SOCKET RECIPIES REQ. WORK INCLUDES REPLACING MEYERS FIRED DISCONNECTS AND SERVICE WIRD TO TRAILERS THIS PERMIT COVERS WORK ON THE FOLLOWING 5-LOTS
 Date Applicant Signature owner-agent

White-Building Department Yellow-Applicant Pink-Electrical Inspector Green-Clerk-Treasurer Gold-County Auditor

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

592-5556

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Joe Goodell - Marvree Valley Address 538 Huddle -
Electrical Contractor SELF Telephone No. 5929906
Address 538 Huddle -
General Contractor _____ Telephone No. _____
Address _____

PERMIT NO. 01319

Location of Project 538 Huddle Cost of Project _____

Work Information: Residential Commercial Industrial
New Service Change Rewiring Additional Wiring

Brief Description of Work: change electric service to mobile home

Size of proposed service entrance 100 Number of new circuits _____

Type of proposed service entrance _____ Underground Overhead _____

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft

Additional Information: REPLACE THE EXISTING FUSED DISCONNECT
AND SERVICES TO 5 EXISTING TRAILERS

PERMIT FEE \$ 50.00

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service: and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 210-8 N.E.C.

Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date 3-6-87 Applicant's Signature Joe Goodell

	1-9	9
A	2 15	14
B	1-18	18
C	1-9	9
D	1-8	8
E	1-11	11

69

F-1 1 Mobil Home shall be supplied with a M.H. Electrical cord with

Wang
2 had
rebar

CITY OF NAPOLEON
255 W. Riverview
NAPOLEON, OHIO 43545

message

reply

to JOE GOODALL
MAHON VALLEY TRAILER CT.
538 HUDDLE RD

subject NEW ELECTRIC SERVICES
ENCLOSED FIND YOUR PERMIT
AND 5- METER SOCKET RELIESES.

PLEASE FILL IN THE LOT NO'S,
ON THE METER SOCKET RELIESE
AND LET ME KNOW WHICH
LOTS THEY ARE FOR,
THE M.S. RELEASE IS REQUIRED IN ORDER FOR YOUR CONTRACTOR
TO OBTAIN A METER SOCKET.

date 3-11-87 signed ELOON HUBER

SENDER: Mail white and pink copies with carbon intact.

RECEIVER: Reply, retain white copy, return pink copy.

1 100 amp disconnect required
2 New attachment receptacles and wire
3 New ground rods and wires

- E-5 1 No plug receptacle direct connectors
2 New ground rod & wires
all new service 100 amp needed
- E-6 1 Service direct connected
2 Upgrade to 100 amp
- E-7 Service direct connected
Upgrade to 100 amps
Wires in trees
- E-8 Service direct connected
Upgrade to 100 amps
Wires in trees
New ground and pad needed
- E-9 Upgrade to 100 amp
new ground rod needed & wires
- E-10 Upgrade entire service to 700 amp
- E-11 Upgrade entire service to 100 amp
- D-8 Upgrade to 100 amp
cannot see plug disconnected
- C-9 Plug disconnected loose and blowing
on cement block
Upgrade entire service
- D-7 wires not protected
Upgrade to 100 amp entire service

D-7-D-C upgrade to 100 amps
C-8-C-1 and install plug attached

C-8 1/2" UF cable running on top of
concrete slab

D-5 Receptacle plug connector box
off post and laying on ground

D-4 Wires laying on ground

D-4-D-5 upgrade call services
C-6-C-5 to 100 amps install new
plan for meter socket and
disconnect

D-3-D-2 Upgrade service to 100 amps
C-4-C-3 wire for service not needed
change cable - wires loose
under C-4 with no tape
and connector by Guyon
Block under trailer

C-2-D-1
Upgrade services to 100 amps no
attachment plugs

Washer Dryer handling

install receptacle for dryer in box
not on extension plug connector
for dryer receptacle box to

Pool circuit pump shall be on
GFI breaker
Remove plug receptacle next
to pool pump fuse box

A-15 - ~~A-17~~ Upgrade services to 100 amp
B-18 - B-17. frayed cords in deteriorated
condition

A-14 Upgrade services to 100 amp
B-16 service cable for B-16 replace
with mobile serviceable

A-13 - A-12 Upgrade services to 100 amp
B-15 - B-14

A-10 - A-11 Upgrade services to 100 amp
B-13 - B-12 install new service cord

B-11 Disconnect Box on ground

A-9, A-8 Upgrade services to 100 amp
B-11 B-10 change service cords

A-7 A-6 Upgrade services to 100 amp
B-9

B-7 - B-8 Upgrade service
5 - A-4

A-4-A5 Upgrade

B-3-B-4

A-3-A-2 Upgrade services

B-1 Accepted for changing by services
A-2 Upgrade service

AA-1

AA-2

AA-3

200 AMP service

AA-4

AA-5

AA-6

200 AMP service

AA-7

AA-8

AA-9

400 AMP service

