

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name BUILDING ON CORNER OAKWOOD & RAILROAD ST.

Address

City NAP State OH

Approved

Violation

Electrical Contractor JIM SPEISER

Remarks:

Code Reference

NOTE: THIS IS THE CONCRETE BLOCK BLDG ON THE EAST SIDE OF OAKWOOD JUST SOUTH OF THE RAILROAD TRACKS.

Plug unused openings, Dead front Plate required in C/B Main, Service OK

No Entry to Bldg. 3:00 Pm

Compliance Time

Inspectors Signature M. Howes

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector