

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 73-79 Issued 6-20-79
date

Job Location 172 EAST Railroad St.
address

Lot on railroad R/W
sub-div or legal discript

Issued By R.E. Johnson
building official

Owner Woods Auto Supply 599-4015
name tel.

Address 907 Oakwood Avenue

Agent Wickes Buildings 592-0966
builder-eng.-etc. tel.

Address Box 62 Napoleon, Ohio

Description of Use Commercial garage

Residential _____
no. dwelling units

Commercial XX Industrial _____

New XX Add'n. _____ Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 18,000.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	\$35.00	\$26.25	\$61.25
<input checked="" type="checkbox"/> ELECTRICAL	18.00	8.25	26.25
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING Variance granted 5-17-79		0	
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$87.50
LESS MIN. FEES PAID _____			0
			<small>date</small>
BALANCE DUE.....			\$87.50

ZONING INFORMATION

district I-1	lot dimensions SEE SITE PLAN	area	front yd	side yds	rear yd
max hgt ok	no pkg spaces 7 req'd.	no ldg spaces n/a	max cover ok	petition or appeal req'd variance	date appr 5-17-79

WORK INFORMATION:

Size: Length 48' Width 30' Stories 1 Ground Floor Area 1440sq'

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: new service entrance and wiring. INCLUDES A.C. IN BLDG @ 907 OAKWOOD AVE.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: CALL FOR INSPECTIONS MARKED ON ATTACHED SHEET:

Date 6/21/79 Applicant Signature [Signature] Wickes Buildings
owner-agent

PAID

JUN 21 1979

CITY OF NAPOLEON

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard	9/15/79	N.K.	<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					

FINAL 12/7/79 N.H.
PARTIAL 9/15/79 N.K.

9/15/79
 INSPECTIONS, CORRECTIONS, ETC.

CITY OF NAPOLEON
Engineering Department
APPLICATION FOR

ELECTRICAL PLAN APPROVAL
(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.
FOR ENGINEERING OFFICE USE ONLY.

App. No. 73-79
Date Received 6-18-79
Received By ROD.
Estimated Cost \$18,000

Minimum Fees

A. Structural 35.00
B. At 1.75 Per 100 Ft.² 26.25
A. plus B. STRUCT. 61.25
ELECTRIC - 26.25

1. Owner's Name Wood's Auto Supply, Inc.
Address 907 Oakwood Ave
Napoleon, OH Tel. 599-4015

2. Owner's Agent or Submitter
Wicker Building, Box 63, Napoleon
Address
Tel. 592-0966

3. Plans Prepared By:
A. Architect
B. Engineer J. Eckhoff
C. Other
\$87.50

4. Name of Job and Description of Building, Store, Church, Etc.
Commercial Garage

5. Location of Project: 172 EAST RR ST,
CORNER of Oakwood & Depot St. Zone:
Lot # Subdivision Section

6. Building Information:
Commercial Industrial New Construction
Addition Remodel

7. Size: Length 48 Width 30
Total Square Ft. Per Floor 1440

5-19-1979

8. Size Service Entrance Amp.
9. All electrical wiring shall be installed in accordance with the National Fire Protection Association, Bulletin No. 13, "National Electrical Code". All wiring shall also conform to the requirements of the Ohio Building Code for the occupancy indicated.

10. Additional Information:

Signature of Applicant A. J. Galvin Date July 30, 1979

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - Plan Examiner

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name WOODS AUTO SUPPLY

Address 172 E. RAILROAD ST

City NAP. State O

Approved _____

Violation _____

Electrical Contractor JIM SPEIKER

Remarks:

Code Reference

Remarks	Code Reference
<u>Service 100A - 3φ Panel OK 9-15-79</u>	

Compliance Time _____

Inspectors Signature M. Jones

Copies To: _____

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 12-7-79

Permit No. 73-79

Type of Inspection FINAL

Type of Occupancy GARAGE

Project Name 172 E RAILROAD ST

Address WOODS AUTO SUPPLY

City NAP State OH

Approved [checkmark]

Violation

Electrical Contractor SPEISER

Remarks:

Code Reference

Exit lights ? NOT REQ'D!

Compliance Time

Inspectors Signature [Signature]

Copies To:

White - Applicant Yellow - Engineering Pink - Electrical Inspector

