

Date: 8-2-76

TO: Electric Distribution Superintendent
FROM: The Building Inspector - Building Department

Please confirm the installation of 100 AMP. electrical

service entrance, located AT REAR OF EXISTING BLDG TO

RIGHT OF BACK DOOR, (OVERHEAD SERVICE)

at the following address: 737 STRONG STREET,

Approved OK Not Approved

Richard
Electric Supt.

8-3-76

Date

Remarks:

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Owner Name Elmora Gunter
 Address 737 Strong Street
 Builder Name Cochran Electric
 Address 525 N. Perry Street Tel. 592-0891

Lot Information:
 Street No. 737 Strong Street
 Lot 216 Subdivision Sheffields 3rd Add.
 Lot Dimensions 40' x 44' x 40' x 44' Lot Area 5,760 Sq. Ft.
 Yard Set Back: Front 10' Rear 10'
 Side 10' Side 10'

Zoning "B" Intended use of Building: New 100 amp electric service entrance

Building Information:

Single X Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length _____ Width _____ No. of Stories _____
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring New 100 amp Electric Heating _____ Electrical Appliances X (1)
 Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____
 Additional Information: _____

Date 8-4-76 Applicant Signature Elmora Gunter Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work _____
 Comments: 8/9/76: INFORMED COCHRAN ELECT. CO. PROVIDE VAPOR SEAL IN CONDUIT BETWEEN METER BASE & PANEL. Also SERVICE ENTRANCE & PANEL INSPECTED AND APPROVED BY HAWES 8/17/76

Certificate of Occupancy Issued _____ Inspector _____
 _____ Pink - Engineer

Permit No. 571-76
 Issued August 3, 1976
 By W. J. Carter Building Inspector
 Valuation \$200.55

Fees	Base	Plus	Total
Construction			
Plumbing			
Electrical	<u>\$3.00</u>	<u>\$1.00</u>	<u>\$4.00</u>
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
TOTAL	<u>\$3.00</u>	<u>\$1.00</u>	<u>\$4.00</u>

571-76

OVER HEAD
LOCATED TO REAR OF HSE
TO RIGHT OF BACK-DOOR

CITY OF NAPOLEON
ENGINEERING DEPARTMENT
APPLICATION FOR ELECTRICAL WORK
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name Elnora Gunter Address 737 Strong Street
Contractor's Name Cochran Elec. Address 525 N. Perry Tel. 572-0891

LOT INFORMATION:

Location of Project 737 Strong St. Zoning District

BUILDING INFORMATION:

Single Family Double Family Multiple Family
New Construction Existing Addition
Replacement Remodel Service Change

Size: Total Square Foot Per Floor No. of Stories

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only YES (Yes or Not)
ONLY 1 NEW CIRCUIT
Total Number of New Circuits (20) Excluding Appliance Circuits 18

APPLIANCE CIRCUITS: (Indicate quantity)

Electric Range Range Hood Clothes Dryer Dishwasher
Air Conditioner Attic Fan Blower Room Exhaust Fan
Tapstal Hot Water Heater Electric Oven
Require Temporary Electric NO (Yes or No)

Note: G.F.T.C. required for all temporary electrical with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$330.55

Date August 8, 1976 APPLICANT'S SIGNATURE Elnora Gunter
OWNER CONTRACTOR-AGENT

NOT REWIRING HSE!

1. - 1.00
3.00 Base
4.00