



City of Napoleon, Ohio

Department of Public Works

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

August 3, 2015

820 Strong Street
Napoleon, OH 43545

Attn: Richard Cobb

Re: 820 Strong Street Sewer Connection

Dear Mr. Cobb,

Thank you for your prompt response to our Illegal Sewer Connection letter. Our preliminary inspection revealed that your property had four potential illegal sewer connections. A final inspection showed that three offending connections have been sufficiently capped off and redirected with one connection to remain as it is connected to a drain tile not leading to the sanitary sewer; your property is in compliance.

Enclosed is a drawing denoting that the above referenced connections have been addressed. A copy will also be kept on record in the City of Napoleon's Engineering Department. If you have questions or require any additional information, please contact our office at 419-592-4010.

Yours truly,

Chad E. Lulfs, P.E., P.S.
Director of Public Works
City of Napoleon, Ohio

Encl.

cc: Monica Irelan, City Manager
Trevor Hayberger, City Law Director
Jeff Rathge, Operations Superintendent
Marty Crossland, Staff Engineer