



City of Napoleon, Ohio

Department of Public Works

255 West Riverview Avenue, P.O. Box 151

Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., Director of Public Works

Telephone: (419) 592-4010 Fax: (419) 599-8393

www.napoleonohio.com

July 8, 2015

1540 Thershan Drive
Napoleon, OH 43545

Attn: William Vocke

Re: 1540 Thershan Drive Sewer Connection

Dear Mr. Vocke,

Thank you for your prompt response to our Illegal Sewer Connection letter. Our preliminary inspection revealed that your property had three illegal sewer connections that were surrounded by sidewalks. Therefore, the City will allow these three downspouts to remain tied into the sanitary sewer. If in the future the existing sidewalks are removed, moved or replaced the existing connections will need to be capped off permanently below grade and the downspouts will need to have a new legal outlet installed.

Enclosed is a drawing denoting that the above referenced connections have been addressed. A copy will also be kept on record in the City of Napoleon's Engineering Department. If you have questions or require any additional information, please contact our office at 419-592-4010.

Yours truly,

Chad E. Lulfs, P.E., P.S.
Director of Public Works
City of Napoleon, Ohio

Encl.

cc: Monica Irelan, City Manager
Trevor Hayberger, City Law Director
Jeff Rathge, Operations Superintendent
Marty Crossland, Staff Engineer

SCANNED

1540 THERSHAN DRIVE

1520

DATE: 7-8-15

INSPECTED BY: MANTY CROSSLAND

INVESTIGATION OF ILLEGAL SEWER CONNECTIONS REVEALED THREE VIOLATIONS. THESE MAY REMAIN TIED INTO THE SANITARY SEWER UNTIL FUTURE SIDEWALK REMOVAL OR REPLACEMENT OCCURS. THE DOWNSPOUTS WILL NEED TO BE CORRECTED AT THAT TIME.

1540

MAY STAY IN TO PREVENT ICE ON SIDEWALKS

1"=20'

12" Stm.

10"

SCANNED

