

**CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT
(1, 2 or 3 Family Dwelling)**

Permit No. 599-76
 Issued 9/12/76
 By James W. ...
 Building Inspector

Valuation \$4,000.00

Fees	Base	Plus	Total
Construction	\$15.00	--	\$15.00
Plumbing			
Electrical			
Heating			
Water Tap			
Sewer Tap			
Temporary Elec.			
TOTAL	\$15.00	--	\$15.00

Owner Name Donald Steele
 Address 1127 Willard Street
 Builder Name Paul Hironaka
 Address 130 Maroon Street Tel. 592-5601

Lot Information:
 Street No. 1127 Willard Street
 Lot 14 Subdivision Highland's 2nd
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Zoning R-10 Intended use of Building: 4 1/2" WALLING ALUMINUM SIDING ON

Building Information:
 Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length _____ Width _____ No. of Stories _____
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical: Wiring _____ Electric Heating _____ Electrical Appliances _____
 Plumbing: Fixtures or Traps _____ Warm Air Heating _____ Hot Water Heating _____

Additional Information: CONTRACTOR MUST CONTACT THE CITY FOR REMOVAL OF CONDUCTIONS
IF METER BASE IS REQUIRED AND PROVIDE AN 18"x18"x3/4" WOOD BACKER FOR THE METER BASE.
 Date 9-18-76 Applicant Signature Donald Steele
 Owner - Builder - Agent

NOTE: SIDING TO BE GROUNDING & BONDED IN AN APPROVED MANNER, SEC. 604.4

Inspection Record:

Work Started	_____	Foundations	_____	Plumbing, Heating	_____
Set Back, Side Lines	_____	Plumbing (Rough In)	_____	And Air Conditioning	_____
Excavation	_____	Erecting Frame	_____	Roof	_____
Footing	_____	Electrical Work	_____		_____

Comments: 10/14/76 PROJECT COMPLETED, PROVIDE PROPER GROUNDING
AND BONDING PLUP

Certificate of Occupancy Issued _____
 Pink - Engineer Inspector

CITY OF NAPOLEON
BUILDING & ZONING INSPECTION DEPARTMENT
FIELD CORRECTION NOTICE

LOCATION 1127 Willard Street PERMIT NO. 599-76

ISSUED TO Donald Steele
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Emil Fitzenreiter

Upon inspection, violations of the Electrical and Building Code Sec. 864.4 of B.O.C.A. and 250-44 of NEC were in evidence.

The following orders are hereby issued for their correction: Entire dwelling must be properly grounded and bonded in an approved manner. Enclosed you will find a copy of AlSCO Anaconda Inc. installation instructions. If you don't start installing siding in accordance to manufacturers recommendations I will have to insist you bond by strapping in back of the siding. Also, you have been asked before to contact the Building Dept 4 hours after the project is started.

CORRECTED AND RE INSPECTED BY [Signature] 10/14/76

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE October 13, 1976

DATE September 29, 1976

BY [Signature]
INSPECTOR

FILE COPY

CITY OF NAPOLEON
BUILDING DEPARTMENT
APPLICATION FOR CONSTRUCTION PERMIT
(PLEASE PRINT OR TYPE)

I, the undersigned hereby make application for the construction, installation, replacement or alteration as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's Building Code for 1, 2 and 3 Family Buildings.

Owner's Name DONALD STEELE Address 1127 Willard ST,
Builder's Name EMIL FITZREITER Address 830 MOUROY ST Tel. 592 5691

NOT INFORMATION: (Not required for roofing or siding job.)

Location of Project 1127 WILLARD Lot # 1
Subdivision LOT 14 HIGHLAND 2ND Lot Area _____ Sq. Ft. _____
Front Set Backs: Front _____ Rear _____ Left Side _____
Right Side _____ Zoning District _____

BUILDING INFORMATION:

Single Double _____ Multiple _____ New Construction _____

Addition _____ Remodel Attached Garage _____

Detached Garage _____ Accessory Building _____ Replacement _____

Brief Description of Work: INSTALL ALUMINUM SIDING
PORCH RAILS, 3 REPLACEMENT WINDOWS

Class: Length _____ Width _____ No. of Stories _____
Floor Area: 1st Floor _____ Sq. Ft. 2nd Floor _____ Sq. Ft.
3rd Floor _____ Sq. Ft. Basement _____ Sq. Ft.
Unfinished Attic _____ Garage _____
Foundation: Piers _____ Full Basement _____ Partial Basement _____
Concrete _____ Thickness _____ Block _____ Stone _____
Walls: Frame _____ Block _____ Brick _____ Other _____

Specific Type of Exterior Siding ALSO LIGHTING LOCK

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITIONS OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO 1/4"=1'-0" SCALE. PLOT PLAN DRAWN TO 1/8"=1'-0" SCALE.

ESTIMATED COST OF COMPLETED PROJECT: 4000⁰⁰

DATE 9/16/76 APPLICANT'S SIGNATURE Emil Fitzreiter
OWNER-BUILDER-AGENT